

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 50-51-1282943
Name of Facility: Imagine Schools-Chancellor Campus
Address: 3333 High Ridge Rd
City, Zip: Boynton Beach 33426

Correct By: Next Inspection
Re-Inspection Date: None

Type: Private Charter School
Owner: Imagine Schools-Chancellor Campus
Person In Charge: Stephanie Standley Phone: 561-585-1189
PIC Email: Stephanie.standley@imagine-chancellor.com

Inspection Information

Purpose: Routine
Inspection Date: 3/25/2026

Begin Time: 12:56 PM
End Time: 02:49 PM

Additional Information

FEMALES 529
MALES 506
CENSUS 1035

As per section 120.695, Florida Statutes (FS) this form will serve as a "Notice of Non-Compliance" for any violation noted. Items marked below violate one or more of the requirements of Chapter 6A-2.0040 Florida Administrative Code (FAC). Sanitation Standards in K-12 Private Schools and section 468. Florida Building Code (FBC), Schools, Colleges, and Universities. Violations must be corrected within the time period indicated in the results section above. Continued operation of this facility without making these corrections is a violation of section 6A-2.0040, FAC, and section 468 FBC. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 13. Disinfectants	SAFETY
IN 1. School Site	IN 14. Handwash Facilities	IN 25. First Aid Kit
OUT 2. Playground	IN 15. Soap Dispensers	DIAPER CHANGING STATION
IN 3. Athletic Equipment	NA 16. Showers	NA 26. Location/Sanitizers
BUILDING	NA 17. Shower Water Temperature	NA 27. Changing Station & Mats
NA 4. Construction	WATER SUPPLY	NA 28. Handsink
OUT 5. Maintenance & Repair	IN 18. Approved Source	NA 29. Garbage Can
OUT 6. Lighting Standards	IN 19. Drinking Fountains	ANIMAL HEALTH AND SAFETY
IN 7. Heating, Ventilation, A/C	LIQUID WASTE	NA 30. Vaccination
IN 8. Natural Ventilation	IN 20. Sewage Disposal	NA 31. Animal Maintenance/Aggressive Animals
IN 9. Mechanical Ventilation	IN 21. Solid Waste	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	PEST CONTROL	NA 32. Maintenance/Complaint
IN 10. Provided/Accessible	IN 22. Pest Control	IN 33. Other
IN 11. Toilet Floor Drains	IN 23. Brush /Trash	
IN 12. Toilet Facilities	IN 24. Water Collection/Drainage	

IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

General Comments

No General Comments Available

Email Address(es): mary.salas@imagine-chancellor.com;
Stephanie.standley@imagine-chancellor.com

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #2. Playground

Damage playground rubber stairs case covert.

Playground & equipment shall be safe, structurally sound, vermin proof, & shall not have jagged or sharp projections.

CODE REFERENCE: Playgrounds and Athletic Equipment. 6A-2.0040(2)(a)(c). Playgrounds shall be constructed & maintained to permit maximum utilization of sites with elimination of sanitary & health hazards including mudholes, fragments of glass, stone & similar obstructions. 468.2.2. Playground & equipment shall be safe, structurally sound, vermin proof, & shall not have jagged or sharp projections. Playground equipment shall be anchored to suitable foundations. Mats, wood chips, or sand shall be used under climbing equipment, slides, & swings.

Violation #5. Maintenance & Repair

Window blinds damage/broken in classroom 128, 238, 201, 204.

Storage bins on floor by door restrooms in classrooms 135, 239.

Storage of miscellaneous items: Decorations and Storage bins, inside the electrical room.

All facilities shall be maintained in good repair.

CODE REFERENCE: Maintenance & Repair. 6A-2.0040(3)(b)(c). Buildings shall be kept clean & in good repair, free from hazardous conditions, such as loose or broken floor tiles & boards; loose moldings; loose hanging fixtures, pipes, electric wires; & broken plaster. Furnishings & equipment shall be kept clean & in good repair, free of missing parts & sharp edges.

Violation #6. Lighting Standards

Observed classroom 139 and 206 with illumination of 5.6 to 10.0 foot candles. PIC adjusted the Classrooms lights providing illumination of 60.0 foot candles. Corrected on site.

CODE REFERENCE: Lighting Standards. 6A-2.0040(4)(a-b). All instructional spaces shall be capable of providing a minimum illumination of forty (40) foot-candles at normal task level. 468.3.2. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Lina Santiago (006092)
Inspector Contact Number: Work: (561) 274-3167 ex.
Print Client Name: Mary Salas
Date: 3/25/2026

Inspector Signature:

Client Signature: